



Test Report

No. VNHL1908013260HG

Date: August 28, 2019

Page 1 of 3



The following sample was submitted and identified on behalf of the client as below:

SGS Job No. : VNHL1908013260HG
Sample Description : ANPRO SPC FLOORING
Buyer :
Manufacturer :
Characteristic : "PVC+BOT DA+PHU GIA"
Country of Origin : VIETNAM
Sample Receiving Date : AUGUST 09, 2019
Final confirmed Date : AUGUST 09, 2019
Testing Period : AUGUST 09, 2019 TO AUGUST 28, 2019
Test Requested : PLEASE REFER TO THE RESULT SUMMARY.
Test Results : PLEASE REFER TO NEXT PAGE(S).
Result Summary :

Test Requested	Conclusion
Impact Resistance	Data / See results

Signed for and on behalf of
SGS Vietnam LTD



Wong Cho Wing
Hardline and E&E Lab Manager

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>.

Attention is drawn to the limitations of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 90 days only.

SGS Vietnam Ltd HCM Office: 198 Nguyen Thi Minh Khai St, District 3, Ho Chi Minh City, Vietnam t (84-28) 3935 1920 f (84-28) 3935 1921 www.sgs.com
Hai Phong Branch: Workshop X11, Hai Thanh Workshop Area, Hai Thanh Ward, Duong Kinh District, Hai Phong City, Vietnam t (84-225) 355 2722 f (84-225) 355 2724



Test Report

No. VNHL1908013260HG

Date: August 28, 2019

Page 2 of 3

Test results:

Sample description: XXXXXXXXXX SPC FLOORING 150 X 150

1. Test item: RESISTANCE TO IMPACT

Test method: ASTM F1265-03a (2013)

Test condition:

Specimen: 150mm×150mm×5.8mm, 3pcs

Steel ball: Φ25.4mm, 65g

Height of Impact: 508mm

Number of impact times: 4 times

Lab environmental condition: 25±1℃, 50±5%RH

Test result:

Test item	Test result
Resistance to impact	No break or crack

Remark: This / these test(s) was / were performed by SGS Shanghai's Hardline Lab.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>.

Attention is drawn to the limitations of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.


Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 90 days only.

SGS Vietnam Ltd

HCM Office: 198 Nguyen Thi Minh Khai St, District 3, Ho Chi Minh City, Vietnam t (84-28) 3935 1920 f (84-28) 3935 1921 www.sgs.com

Hai Phong Branch: Workshop X11, Hai Thanh Workshop Area, Hai Thanh Ward, Duong Kinh District, Hai Phong City, Vietnam t (84-225) 355 2722 f (84-225) 355 2724

Member of the SGS Group (SGS SA)

PHOTO OF SUBMITTED SAMPLE FOR TESTING


REPORT RESULTS REFER TO SUBMITTED SAMPLE (S) ONLY

***** End of Report *****

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>.

Attention is drawn to the limitations of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 90 days only.